



2294

**Interscience Fire Laboratory**  
Building 63  
Haslar Marine Technology Park  
Haslar Road, Gosport  
Hampshire PO12 2AG  
United Kingdom

Tel. : +44 (0) 20 8692 5050  
Fax.: +44 (0) 20 8692 5155  
Email: [firetesting@intersciencecomms.co.uk](mailto:firetesting@intersciencecomms.co.uk)

**Test Report: ICL/H25/17730**

**International Maritime Organisation.**  
**INTERNATIONAL CODE FOR APPLICATION**  
**OF FIRE TEST PROCEDURES, 2010**  
**(2010 FTP CODE)**  
**Part 2 – Smoke and toxicity test**

**Sponsored By**  
Solar Solve Ltd,  
7 Waldrige Way, Simonside Industrial Park,  
South Shields, Tyne and Wear, NE34 9PZ, UK

Only valid for official SOLASOLV® wine software which has been supplied from the UK

**Registered Office:** Building 63, Haslar Marine Technology Park, Haslar Road, Gosport PO12 2AG, UK  
Email: [firetesting@intersciencecomms.co.uk](mailto:firetesting@intersciencecomms.co.uk); Web: [intersciencecomms.co.uk](http://intersciencecomms.co.uk)  
Company Registration 01896939 VAT No. GB 407 5195 54

This report relates only to the specimen(s) tested and shall not be reproduced  
except in full without the written approval of the testing laboratory

Test Report: ICL/H25/17730

**International Maritime Organisation.  
INTERNATIONAL CODE FOR APPLICATION  
OF FIRE TEST PROCEDURES, 2010  
(2010 FTP CODE)  
Part 2 – Smoke and toxicity test**

**Sponsored By**  
Solar Solve Ltd,  
7 Waldrige Way, Simonside Industrial Park,  
South Shields, Tyne and Wear, NE34 9PZ, UK

**1 Introduction**

International Maritime Organisation, INTERNATIONAL CODE FOR APPLICATION OF FIRE TEST PROCEDURES, 2010 (2010 FTP CODE) Part 2 - "Smoke and Toxicity" requires test to be carried out using the test apparatus and methodology detailed in ISO 5659-2: 1994. Toxicity measurements are carried at when maximum specific density of smoke is reached (DmST) is reached.

The principle of the test method, ISO 5659-2, is to expose a material to specified thermal conditions of pyrolysis and combustion in a continuous procedure. The change in optical density of the smoke produced when dispersed within a fixed volume of air is recorded throughout the period of test.

The test method provides a means for the comparative assessment of products, however, it does not model a real fire situation and the results cannot therefore be used to describe the fire hazard of materials under actual fire conditions.

**2 Description of Test Specimens**

The description of the specimens given below has been prepared from information provided by the sponsor of the test. All values quoted are nominal, unless tolerances are given.

The product was a 0.5mm thick film referenced "SOLASOLV Solar Control Window Film"

The sponsor of the test has supplied a product safety data sheet relating to the product tested and this is held in our file relating to this investigation.

**3 Conditioning of Specimens**

The specimens were received on 9<sup>th</sup> July 2025.

The specimens were conditioned to constant mass at  $23 \pm 3^{\circ}\text{C}$  and  $50 \pm 5\%$  RH, before testing.

**4 Date of Test**

The tests were performed on the 8<sup>th</sup> August 2025.

This report relates only to the specimen(s) tested and shall not be reproduced  
except in full without the written approval of the testing laboratory

## 5 Test Procedure

The test was performed in accordance with the procedure called up in International Maritime Organisation, INTERNATIONAL CODE FOR APPLICATION OF FIRE TEST PROCEDURES, 2010 (2010 FTP CODE) Part 2- “Smoke and Toxicity” and this report should be read in conjunction with that Standard.

The product was tested with a non-combustible Backing board  $12.5 \pm 3$  mm thick having the density of  $950 \pm 100$  kg/m<sup>3</sup>.

Gas samples were taken at DmST and analysed using FTIR apparatus having:

Gas cell having a volume of: 1.33 l  
 Length of gas sampling line: 2 m  
 Inner volume gas sampling tube: 56 cm<sup>3</sup>  
 Capacity of gas sampling pump: 3 l/min  
 Sampling Response Period (SRP) 30Sec

## 6 Test Results

The test results apply to the sample as received tested after conditioning. The test results relate only to the behaviour of the specimens of the product under the particular conditions of test; they are not intended to be the sole criterion for assessing the potential smoke and toxic emission hazard of the product in use.

The test results relate only to the specimens of the product in the form in which they were tested. Small differences in the composition or thickness of the product may significantly affect the performance during the test and will therefore invalidate the test results. It is the responsibility of the supplier of the product to ensure that the product, which is supplied, is identical with the specimens, which were tested.

Because of the nature of reaction to fire testing and the consequent difficulty in quantifying the uncertainty of measurement of reaction to fire, it is not possible to provide a stated degree of accuracy of test results. Uncertainty measurement has not been taken into account when presenting the test results.

**Smoke emission:** The maximum Ds values, average of three tests in each mode, are given below.

| Test Mode        | 25kW m <sup>-2</sup> | 25kW m <sup>-2</sup> with pilot flame | 50kW m <sup>-2</sup> |
|------------------|----------------------|---------------------------------------|----------------------|
| Ds max (average) | 26.55                | 20.29                                 | 72.98                |

Full results are given in Appendix 1.

IMO Part 2 APPENDIX 2 FIRE TEST PROCEDURES FOR TOXIC GA GENERATION

**Toxic gas emission:** Toxic gas emission result are summarised in Table 1 below:

| Gas Species                         | Average Concentration in each mode (ppm) | Average Concentration in each mode (ppm) | Average Concentration in each mode (ppm) |
|-------------------------------------|--|--|--|
|                                     | 25 kWm <sup>-2</sup>                     | 25 kWm <sup>-2</sup> with pilot          | 50 kWm <sup>-2</sup>                     |
| Carbon Dioxide, CO <sub>2</sub>     | 29                                       | 16                                       | 46                                       |
| Carbon Monoxide, CO                 | ND                                       | ND                                       | ND                                       |
| Hydrogen Chloride, HCl              | ND                                       | ND                                       | ND                                       |
| Hydrogen Bromide, HBr               | ND                                       | ND                                       | ND                                       |
| Hydrogen Cyanide, HCN               | ND                                       | ND                                       | ND                                       |
| Hydrogen Fluoride, HF               | ND                                       | ND                                       | ND                                       |
| Sulphur Dioxide, SO <sub>2</sub>    | ND                                       | ND                                       | ND                                       |
| Nitrous Fumes, NO <sub>x</sub>      | ND                                       | ND                                       | ND                                       |
| Acrylonitrile, CH <sub>2</sub> CHCN | ND                                       | ND                                       | ND                                       |
| Acrolein, CH <sub>2</sub> CHCHO     | ND                                       | ND                                       | ND                                       |

Where ND = not detected Full results are given in Appendix 2.

7

**Requirements**

**Smoke:**

An average (Dm) of the maximum of Ds of three tests at each test conditions shall satisfy the following requirements:

| Product type                   | Ds max |
|--------------------------------|--------|
| 1. Bulkhead, Lining or ceiling | 200    |
| 2. Primary deck covering       | 400    |
| 3. Floor Covering              | 500    |
| 4. Plastic pipes.              | 400    |

**Toxicity:** The gas concentration measured at each test condition shall not exceed the following limits in any of the three test modes:

| Gas Species                      | Requirements (ppm)              |
|----------------------------------|---------------------------------|
| Carbon Monoxide, CO              | ≤1450                           |
| Hydrogen Chloride, HCl           | ≤600                            |
| Hydrogen Bromide, HBr            | ≤600                            |
| Hydrogen Cyanide, HCN            | ≤140                            |
| Hydrogen Fluoride, HF            | ≤600                            |
| Sulphur Dioxide, SO <sub>2</sub> | ≤120 (≤200 for floor coverings) |
| Nitrous Fumes, NO <sub>x</sub>   | ≤350                            |

This report relates only to the specimen(s) tested and shall not be reproduced except in full without the written approval of the testing laboratory

**8 Conclusion**


When tested in accordance with the procedure called up in International Maritime Organisation, Fire Test Procedure Code Part 2 Appendix 1 and Appendix 2 we confirm that all the requirements for the test method in this normative document have been met and the result has been determined according to that normative document. The results show that the product meets the requirements for use as Bulkhead, Lining or ceiling and Primary deck covering

**Prepared by**



**C. B. Chong**  
**Fire Scientist**

**Approved by**



**S. Kumar**  
**Technical Manager**

**Date of Issue: 26<sup>th</sup> August 2025.**

Only valid for official SOLASOLV® window film which has been supplied from the UK

**Appendix 1**  
**Smoke data**

**25kW/m<sup>2</sup> without pilot flame**


| <b>Run</b>                                     | <b>Maximum specific density (D<sub>Smax</sub>)</b> | <b>Time to maximum specific density (s)</b> | <b>Time to ignition (s)</b> |
|--|--|---|-----------------------------|
| 1  | 15.55  | 1195.00                                     | No ignition                 |
| 2  | 34.60  | 1200.00                                     | No ignition                 |
| 3  | 29.51  | 1199.00                                     | No ignition                 |
| <b>Average</b>                                 | <b>26.55</b>                                       | <b>1198.00</b>                              |                             |
| Maximum smoke density sampling time (DmST) Sec |  |   | 1165.00                     |

**25kW/m<sup>2</sup> with pilot flame**


| <b>Run</b>                                     | <b>Maximum specific density (D<sub>Smax</sub>)</b> | <b>Time to maximum specific density (s)</b> | <b>Time to ignition (s)</b>                        |
|--|--|---|--|
| 1  | 13.34  | 1182.00                                     | Time to ignition = 40s.<br>Time to flameout = 64s. |
| 2  | 22.81  | 1201.00                                     | No ignition  |
| 3  | 24.73  | 1198.00                                     | No ignition  |
| <b>Average</b>                                 | <b>20.29</b>                                       | <b>1193.67</b>                              |  |
| Maximum smoke density sampling time (DmST) Sec |  |   | 1152.00  |

**50kW/m<sup>2</sup> without pilot flame**


| <b>Run</b>                                     | <b>Maximum specific density (D<sub>Smax</sub>)</b> | <b>Time to maximum specific density (s)</b> | <b>Time to ignition (s)</b> |
|--|--|---|-----------------------------|
| 1  | 78.53  | 1066  | No ignition                 |
| 2  | 79.34  | 1015  | No ignition                 |
| 3  | 61.07  | 1200  | No ignition                 |
| <b>Average</b>                                 | <b>72.98</b>                                       | <b>1094</b>                                 |                             |
| Maximum smoke density sampling time (DmST) Sec |  |   | 1036.00                     |



**Graph 1 – Optical Density v Time curve for 25 kWm<sup>-2</sup> without pilot flame**



**Graph 2 – Optical Density v Time curve for 25 kWm<sup>-2</sup> with pilot flame**



**Graph 3 – Optical Density v Time curve for 50 kWm<sup>-2</sup> without pilot flame**

Only valid for official SOLASOLV® window film which has been supplied from the UK

**Appendix 2  
Toxicity Data**

**25kW/m<sup>2</sup> without pilot**

| Gas species                         | Concentration (ppm) |       |         |
|-------------------------------------|---------------------|-------|---------|
|                                     | Run 2               | Run 3 | Average |
| Carbon Dioxide, CO <sub>2</sub>     | 26                  | 32    | 29      |
| Carbon monoxide, CO                 | ND                  | ND    | ND      |
| Oxides of Nitrogen, NO <sub>x</sub> | ND                  | ND    | ND      |
| Sulphur dioxide, SO <sub>2</sub>    | ND                  | ND    | ND      |
| Hydrogen Chloride, HCl              | ND                  | ND    | ND      |
| Hydrogen Bromide, HBr               | ND                  | ND    | ND      |
| Hydrogen Fluoride, HF               | ND                  | ND    | ND      |
| Hydrogen Cyanide, HCN               | ND                  | ND    | ND      |

Where ND= Not detected.

**25kW/m<sup>2</sup> with pilot**

| Gas species                         | Concentration (ppm) |       |         |
|-------------------------------------|---------------------|-------|---------|
|                                     | Run 2               | Run 3 | Average |
| Carbon Dioxide, CO <sub>2</sub>     | 17                  | 15    | 16      |
| Carbon monoxide, CO                 | ND                  | ND    | ND      |
| Oxides of Nitrogen, NO <sub>x</sub> | ND                  | ND    | ND      |
| Sulphur dioxide, SO <sub>2</sub>    | ND                  | ND    | ND      |
| Hydrogen Chloride, HCl              | ND                  | ND    | ND      |
| Hydrogen Bromide, HBr               | ND                  | ND    | ND      |
| Hydrogen Fluoride, HF               | ND                  | ND    | ND      |
| Hydrogen Cyanide, HCN               | ND                  | ND    | ND      |

Where ND= Not detected.

**50kW/m<sup>2</sup> without pilot**

| species                             | Concentration (ppm) |       |         |
|-------------------------------------|---------------------|-------|---------|
|                                     | Run 2               | Run 3 | Average |
| Carbon Dioxide, CO <sub>2</sub>     | 43                  | 49    | 46      |
| Carbon monoxide, CO                 | ND                  | ND    | ND      |
| Oxides of Nitrogen, NO <sub>x</sub> | ND                  | ND    | ND      |
| Sulphur dioxide, SO <sub>2</sub>    | ND                  | ND    | ND      |
| Hydrogen Chloride, HCl              | ND                  | ND    | ND      |
| Hydrogen Bromide, HBr               | ND                  | ND    | ND      |
| Hydrogen Fluoride, HF               | ND                  | ND    | ND      |
| Hydrogen Cyanide, HCN               | ND                  | ND    | ND      |

Where ND= Not detected.

This report relates only to the specimen(s) tested and shall not be reproduced  
except in full without the written approval of the testing laboratory

Only valid for official SOLAS 2016 window film which has been supplied from the UK

Appendix 3



Photo 1: showing the exposed .



Photo 2: Specimens after test 25kW/m<sup>2</sup> without pilot flame.



Photo 3: Specimens after test 25kW/m<sup>2</sup> with pilot flame.

Only valid for official SOLASOLV® window film which has been supplied from the UK



Photo 4: Specimens after test 50kW/m<sup>2</sup> without pilot flame.

Only valid for official SOLASOLV® window film which has been supplied from the UK